

Danfoss A/S

6430 Nordborg Denmark CVR nr.: 20 16 57 15

Telephone: +45 7488 2222 Fax: +45 7449 0949

UK DECLARATION OF CONFORMITY

Danfoss A/S

Danfoss Climate Solutions, Refrigeration & Air Conditioning Controls

declares under our sole responsibility that the

Product category: Filter Driers

Type designation(s): DCR 048, DCR 096, DCR 144, DCR 192

Covered by this declaration is in conformity with the following directive(s), standard(s) or other normative document(s), provided that the product is used in accordance with our instructions.

Pressure Equipment (Safety) Regulations 2016

Туре	TS	PS EN (bar/psig)	Category	Module	Fluid group
DCR 048	-40°C/+70°C (-40°F/+160°F)	46 bar (667 psig)	ı	Α	2 ^c
DCR 096	-40°C/+70°C (-40°F/+160°F)	46 bar (667 psig)	ı	Α	2°
DCR 144	-40°C/+70°C (-40°F/+160°F)	35 bar (500 psig) ^A	1	Α	2 ^c
	-40°C/+70°C (-40°F/+160°F)	46 bar (667 psig) ^B	I	Α	2 ^c
DCR 192	-40°C/+70°C (-40°F/+160°F)	28 bar (400 psig) ^A	I	Α	2 ^c
	-40°C/+70°C (-40°F/+160°F)	40 bar (580 psig) ^B	I	Α	2°

A for usage with strainer or as a receiver application.

EN14276-1:2020 Pressure equipment for refrigerating systems and heat pumps – Part 1: Vessels

BS EN 378-1:2016+A1:2020 Refrigerating systems and heat pumps, Safety and environmental requirements - Basic requirements, definitions, classification and selection criteria.

Equipment used for the above condition must be installed and maintained according to the requirements in BS EN 378-2:2016.

Issued by
DocuSigned by: Date: Date: Approved by DocuSigned by 03/11/2022 03/11/2022 nathan heal Logano Place of issue: Place of issue: 66634 NL, Mexico 66634 NL, Mexico 3236E95E30FB46E.. Signature: Signature: Name: Jonathan Leal Name: Jose Alejandro Tijerina C. Title: Sr Design Engineer Title: Senior Engineering Manager

Danfoss only vouches for the correctness of the English version of this declaration. In the event of the declaration being translated into any other language, the translator concerned shall be liable for the correctness of the translation

^B for "drier" application using all the permissible cores.

^C Use of R744 (CO2) only for subcritical applications